



Department of General Services CAPITAL PROJECTS MANAGEMENT DIVISION

ADDENDUM 3

Claybank Campus Perimeter Security Fence Replacement Project 2500 Claybank Road, Fairfield, CA 94533

August 18, 2020

This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated into those documents. Where provisions of the following supplementary data differ from those of the original bid documents, this addendum shall govern and take precedence.

Bidders are notified that they shall make any necessary adjustment(s) in their estimate on account of this addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified in this addendum.

The clarification and/or additions and/or deletions that are described in this addendum shall be included in the specifications and/or drawings.

This ADDENDUM supersedes the original PROJECT MANUAL and DRAWINGS dated July 15, 2020, amended with Addendum #1 dated August 4, 2020 and Addendum #2 dated August 14, 2020 to the extent that it contradicts them; all other conditions remain unchanged.

Acknowledgement of receipt of this ADDENDUM is required on the bid form.

REQUEST FOR INFORMATION

1. There is conflict in the rail size. Existing rail size is 1 7/8" instead of 2 3/8" as called for on the plans. The razor wire is installed differently than what's shown on the plans as well. Please confirm if we are to match existing or details on C-400 note 2?

New fence and razor wire shall be per details shown on Sht. No. C-400 and Spec. Sec. 323113 Chain Link Fences and Gates.