

**Appendix XIII  
Underground Storage Tank  
Designated UST Operator Visual Inspection Report**

<b>1. FACILITY INFORMATION</b>		
CERS ID	Inspection Date	
Facility Name		
Facility Address	City	ZIP Code
<b>2. DESIGNATED UST OPERATOR INFORMATION</b>		
Name of Designated UST Operator	Phone	
ICC Certification	Certification Expiration Date	
<b>3. COMPLIANCE ISSUES</b>		
<p><i>Identify by number all compliance issues listed</i></p>		
<b>4. CERTIFICATION BY DESIGNATED UST OPERATOR CONDUCTING INSPECTION</b>		
<p><b>I hereby certify that the visual inspection was performed in compliance with California Code of Regulations, title 23, division 3, chapter 16, section 2716 and all information provided herein is accurate.</b></p>		
Designated UST Operator Signature	Date Inspection Report Provided to Owner	

CERS = California Environmental Reporting System, ICC = International Code Council, ID = Identification, NA = Not Applicable, UDC = Under-Dispenser Containment, UST = Underground Storage Tank

## Underground Storage Tank Designated UST Operator Visual Inspection Report

### 5. OWNER/OPERATOR DESCRIPTION OF FOLLOW-UP ACTION

Number the follow up actions to correspond to appropriate compliance issues from Section 3.

### 6. OWNER / OPERATOR ACKNOWLEDGEMENT OF INSPECTION RESULTS

**I have reviewed the results of the designated UST operator inspection report and provided a description of the action(s) taken or to be taken to correct any compliance issues discovered.**

Name of UST Owner / Operator (print)

UST Owner/Operator Signature

Date Signed

### 7. INSPECTION HISTORY

Has each follow-up action of Section 3 from the previous Designated UST Operator Inspection Report been completed appropriately?

*(Attach documentation verifying appropriate service to this report.)*

Yes

No

NA




### 8. RELEASE DETECTION ALARM HISTORY

***Attach a copy of the alarm history report/log to this report.***

Is the monitoring system powered on and in proper operating mode?

Has each alarm since the previous inspection been responded to appropriately?  
*(Attach documentation verifying appropriate service to this report.)*

Have all containment sumps, that have had an alarm since the previous designated UST operator inspection report, been responded to by a qualified service technician?

Yes

No

NA









All answers marked "No" must be described by the designated UST operator in Section 3.

## Underground Storage Tank Designated UST Operator Visual Inspection Report

9. UST SYSTEM INSPECTION					
<p><b>List below and in Section 3 all containment sumps that have had a release detection alarm since the previous Designated UST Operator Inspection Report and have not been responded to by a qualified service technician. Containment sumps listed below require a visual inspection for damage, water, debris, hazardous substance, and proper sensor location.</b></p>					
<p>Is the <b>containment sump</b> free of damage, water, debris, and hazardous substances?</p>					
Containment Sump ID	Yes	No	Containment Sump ID	Yes	No
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<p>Are all sensors in visually inspected <b>containment sumps</b> located to detect a release at the earliest opportunity?</p>				<input type="checkbox"/>	<input type="checkbox"/>
<p>Is the <b>spill containment</b> free of damage, water, debris, and hazardous substances? Is the fill pipe free of obstructions? Is fill cap securely on the fill pipe?</p>					
Spill Containment ID	Yes	No	Spill Containment ID	Yes	No
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<p>Is the <b>UDC</b> free of damage, water, debris, and hazardous substances and all sensors located to detect a release at the earliest opportunity? <input type="checkbox"/> No UDC(s) at this facility</p>					
UDC ID	Yes	No	UDC ID	Yes	No
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<p><input type="checkbox"/> Mechanical float mechanisms used in UDCs.</p>					

All answers marked "No" must be described by the designated UST operator in Section 3.

## Underground Storage Tank Designated UST Operator Visual Inspection Report

<b>10. TESTING AND MAINTENANCE</b>	Yes	No	NA	Date last performed	
Has monitoring system certification been completed within the past 12 months?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Has spill container testing been completed within the past 12 months?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Has overfill prevention equipment inspection been completed within the past 36 months?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Has secondary containment testing been completed within the past 36 months?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Has tank tightness testing been completed within required timeframes?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Has line tightness testing been completed within the required timeframes?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Other Test / Maintenance:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Other Test / Maintenance:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Other Test / Maintenance:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
<b>11. FACILITY EMPLOYEE TRAINING</b>				Yes	No
Have all individuals performing facility employee duties received the required facility employee training within the past 12 months?				<input type="checkbox"/>	<input type="checkbox"/>
<b>13. COMMENTS</b>					
<i>This section may be used to record comments or observations that are not current compliance deficiencies.</i>					

All answers marked "No" must be described by the designated UST operator in Section 3.