

Notice of Exemption

Appendix E


To: Office of Planning and Research
 P.O. Box 3044, Room 113
 Sacramento, CA 95812-3044
 County Clerk
 County of: Solano
 675 Texas St, Suite 6500
 Fairfield, CA 94533

From: (Public Agency): City of Dixon - Engineering Dept
171 South Fifth St
Dixon, CA 95620

FILED

(Address)

OCT 28 2021

Birgitta E. Corsello, Clerk of
 the Board of Supervisors of
 the County of Solano, State of California
 Deputy: 

Project Title: Valley Glen Storm Drain Pump Station Emergency Generator Repair

Project Applicant: City of Dixon, Engineering Department

Project Location - Specific:

1755 Parkway Blvd, Dixon, CA, immediately south of Parkway/Valley Glen Dr

Project Location - City: of Dixon

Project Location - County: Solano

Description of Nature, Purpose and Beneficiaries of Project:

Repairs including 1) Replacement of the cylinder head assembly on the generator's engine; 2 New pump seal on the fuel injection system; 3) Replacement radiator; 4) Full service of the cooling system; 5) Full flush service of the lubrication system; 6) Filter and rejuvenation of the existing fuel in the diesel tank, and 7) Installation of a fuel distribution pump on the diesel tank. Approved by Dixon City Council 10/5/21

Name of Public Agency Approving Project: City of Dixon City Council

Name of Person or Agency Carrying Out Project: City of Dixon Engineering Department

Exempt Status: (check one):

- Ministerial (Sec. 21080(b)(1); 15268);
- Declared Emergency (Sec. 21080(b)(3); 15269(a));
- Emergency Project (Sec. 21080(b)(4); 15269(b)(c));
- Categorical Exemption. State type and section number: 15301.d and 15303.d
- Statutory Exemptions. State code number: _____

Reasons why project is exempt:


Repair of the existing storm drain pump station emergency generator is considered rehabilitation of damaged mechanical equipment to meet current standards (15301.d). A fuel distribution pump will also be added as new feature to the diesel tank and is considered an accessory structure to an existing facility (15303.d).

Lead Agency

Contact Person: Deborah Barr, City Engineer/Director of Utilities Area Code/Telephone/Extension: 707-678-7030

If filed by applicant:

1. Attach certified document of exemption finding.
2. Has a Notice of Exemption been filed by the public agency approving the project? Yes No

Signature:  Date: 10/14/21 Title: City Engineer/Dir of Utilities

Signed by Lead Agency Signed by Applicant

Authority cited: Sections 21083 and 21110, Public Resources Code.
 Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.

Date Received for filing at OPR: _____

Document Posted From
10/28/2021 to _____

Revised 2011

Deputy Clerk of the Board